



## LABORATORIES

A Subsidiary of Mahaffey Associates Pty Ltd ABN 90 001 629 036  
4 Mary Parade Rydalmere NSW 2116  
PO Box 349 Rydalmere BC NSW 1701  
Phone: (02) 9684 2422 Fax: (02) 9684 2310  
Email: bemac@mahaffey.com.au

**Client:** Hydrocon  
**Job Number:** 9378  
**Project:** Product Evaluation  
**Site:** Not Applicable  
**Test Type:** Determining Permeability to Water  
**Test Method:** AS 4456.16 2003

**Manufacture Date:** Not Advised  
**Sampling Date:** 28/09/2007 by Client  
**Test Date:** 9/01/2008

**Exposed Surface Area (mm<sup>2</sup>):** 7850

## Test Report

Sample No.	Permeability			Category	Description
	(µm/s)	(mm/minute)	(m/24hrs)		
A	5300	318.0	460	E	Free Draining
B	4100	246.0	350	E	Free Draining
C	4200	252.0	360	E	Free Draining

Note: the Category and Description given above are those in QMR Q304. That method is similar in principle to AS 4456.16  
Note: the specimens tested were samples core drilled from units.

**Comments:** Nil

David Wilmshurst  
Approved Signatory